

BRIHANMUMBAI MUNICIPAL CORPORATION
MUMBAI FIRE BRIGADE

No.: F3 INSP/R-III/18

Date: 06/03/2024

To,

C.F.O

Sub:- School Inspection Report From Fire & Life Safety Point Of View
Ref:- MFB No. Insp/R-III/18 dated 20.02.2024

Sir,

School Inspection Report From Fire & Life Safety Point Of View is as follows.

1	Name & Address of the School	Ram & Ashok Education Society, Golden Chariot Annexe, Lokhandwala Complex, Andheri W, Mumbai 400053
2	Date of Inspection.	01/03/2024
3	Name of Principal / Building-In-Charge.	Smt. Kulsoom Fatima
4	Composition of the building	Ground + Two (part) floored R.C.C. structure
5	Width of Road -	P.Tondon Road, 04 meters
6	Main Entrance Width - Total Entrance / Exit -	03 meters approx. 01 no. to school premises
7	Structure	R.C.C. building
8	No.of Staircases along with its width	01 staircase of 1.2 meters approx.
9	Common corridor with width	One 1.5 meters approx.
10	Open Spaces Around the School Building	Open space as road
11	Number of classroom	13 classrooms
12	Whether the College Building has mixed Occupancy, If so, What Type and on Which floors?	N.A
13	Offices / Library / Laboratory / Computer Room etc.	Office, IT room, Staff room, Lab room
14	Store Rooms Provided if any	Yes
15	<u>In case of Lifts:</u> Whether lift lobbies are Ventilated direct to outside air.	NA
16	Location of Electric Meter Room & Pump Room.	Ground floor
17	Whether Canteen / kitchen is provided, on which floor & which fuel is used.	Yes, PNG
19	Existing Fire Fighting System & whether in operative condition or not.	Found 6 nos. ABC-type DCP fire extinguisher found provided at prominent places

Recommendations :-


- 1) Main entrance, exit, passages, corridors, open spaces around the building, staircases shall be kept unobstructed.
The entrance and exit shall not be locked during school hours.
Electrical points shall not be overloaded. An electric audit shall be done.
Electric mains shall be switched off before closing the premises.



(PRINCIPAL)

- 5) Smoking, heating, cooking and use of naked flame in school premises shall be strictly prohibited.
- 6) Inflammable and Hazardous material shall not be stored in the school premises.
- 7) P.N.G./L.P.G shall not be used in the pantry area as well as anywhere in the school building.
- 8) A School Fire Management Plan (SFMP) shall be prepared.
- 9) Display signages like "Exit", "Enter", "Emergency Exit", "Assembly Point", "Fire Extinguisher", etc. at appropriate locations. Along with arrow marks for safe & quick evacuation as per the prepared plan
- 10) Automatic fire detection system & Fire alarm system shall be provided in the premises.
- 11) Necessary permission from the competent Municipal authority shall be obtained for the existing shed on the part terrace & terrace. The combustible material used for the shed shall be removed immediately.
- 12) Fire sensitization of staff and fire evacuation drill:
 - a. Fire evacuation & mock drills involving both staff & pupils shall be held regularly.
 - b. In-house office/teaching staff and security shall be trained in operating/maintaining fire extinguishers and summoning of FIRE BRIGADE in case of emergency.
 - c. **Formulate the school Fire Management team as per the attached ANNEXURE I**
- 13) All Fire extinguishers shall be kept in good working condition at all time.
- 14) Good housekeeping shall be maintained.


Note:- This is an inspection report and shall not be considered as Fire safety requirement. Necessary permission & License shall be obtained from concerned Authority.


 Sr S.O. A.S. Khanolkar
 Inspecting Officer

Copy to,

- ✓ 1. Smt. Kulsoom Fatima
2. DO A.E. (B & F) K/W ward
3. MOH K/W ward
4. Office copy




 Dy. Chief Fire Officer
 Mumbai Fire Brigade

